# **CO**<sup>2</sup> Controller

Factory Settings

CO<sub>2</sub> Deadband Set Point: 50 PPM

**CO2 Calibration Set Point: 400 PPM** 

CO<sub>2</sub> Mode:





Max Amp: 10 amps @ 220-240VAC / 50 Hz CO<sub>2</sub> PPM Set Point: Sensor Cord Length (ft/m): 15 / 4.5 CO<sub>2</sub> Control Range (PPM): 400-2000 CO2 Accuracy (PPM): +/- 100 Weight (lbs/kg): 2.1/1 Dimensions (inch/mm): 5.07x4.68x1.95 / 130x120x50 Indoor use only For Altitudes up to 6500 ft / 2000 m Operating Temperature Range (°F/°C): 40-105 / 4-40 Maximum Relative Humidity: 80% IP Rating: IP20

## Dverview

The PPM-B1 CO<sub>2</sub> Controller, with an adjustable CO<sub>2</sub> set point and deadband, offers precise and accurate control of 240-volt CO<sub>2</sub> supplementation devices. Utilizing the built in photocell feature this controller limits CO<sub>2</sub> production to the light hours to maximize savings and increase yields. Featuring three control modes - PPM UP for CO<sub>2</sub> generator use, FUZZY LOGIC for superior accuracy when utilizing a tank and regulator setup, and PPM DOWN if desired. ETL, CE, and FCC approved for safety and dependability.

> Pro-Leaf: Version 5.0 www.pro-leaf.com

## Instructions

 $\star$  The unit takes about 2 minutes to warm up & display PPM readings upon startup.

#### MIN/MAX RECALL 📢

Click both knobs simultaneously to recall and display the recorded PPM MIN/MAX values - reads L XXX, HXXX. The screen will return to normal operation after a period of 5 seconds and the recorded values will be reset.

## Calibration

Place the CO<sub>2</sub> sensor outdoors if possible (or in a room with fresh air ventilation) and press both knobs simultaneously for 3 seconds until the display reads CAL / 400. If necessary, the calibration point can be adjusted by turning the CO<sub>2</sub> PPM knob. Calibration begins automatically after five seconds. During calibration keep the sensor out of direct sunlight, away from sources of CO<sub>2</sub>, and be sure to not breath on the sensor. Allow 10 minutes for the calibration process to complete and stabilize the CO<sub>2</sub> reading. The display will stop flashing the PPM value once the calibration process is complete.

Note about Calibration: The PPM-B1 is factory calibrated, but to ensure precise readings and optimal control it is recommended to place the sensor outside for a period of ten minutes to test, after which the displayed PPM value should be around 400 (this value might be slightly higher in city environments compared to rural environments). In the unlikely event that your controller readings differ greatly from 400 PPM it is then recommended to recalibrate the unit.

#### Error Codes

Error LED will blink if an error occurs.

Please ensure the sensor connection is secure.

If the controller does not reach the CO2 PPM set point within two hours this error will be activated. Press any konb to reset the error.

Please check if the outlet is overloaded or has exceeded the amperage rating. Maximum Amperage is 10 Amps.

The CO<sub>2</sub> sensor is requested for calibration, please follow up the calibration procedure. If the 8888 Err code is still not disappear, please contact your retail store.

# **Real-Time PPM Display**







1000 PPM

PPM UP





PPM-B1

Press knob and turn to set the desired deadband level. Press knob once more to save

Example: When in PPM UP or FUZZY LOGIC mode, if CO2 PPM=1000 PPM and Deadband=50 PPM, then the CO2 output will be activated at or below 1000 PPM and turn off at 1050 PPM. For PPM DOWN, the fan will be activated at or above 1000 PPM and turn off at 950 PPM.

# **Installation Option 1**





#### Secure the unit to a wall

 $\bigstar$  DO NOT attempt to repair this controller. Please contact your retailer for service request information.





### **CO<sub>2</sub> Controller** PPM-B1



## **IMPORTANT MESSAGE**

1.Save these instructions. These safety and operating instructions must be kept in a safe place for future reference.

2. Heed all warnings. All warnings on this product and in the instructions must be observed closely.

3. Follow all instructions. All operating instructions must be followed.

4. If the instructions as provided by the manufacturer are not followed damage to the product may result.

5. Install your controller at least 8 ft away from any devices that produce large amounts of electronic noise, such as electronic ballasts or ozone generators.
6. The output voltages of this controllers receptacles are the same as the input voltage.

The receptacles can only be used in conjunction with the plugs conforming to local safety standards. DO NOT attempt to insert any other plug configuration into the controller receptacles.

7. DO NOT use this controller near a water source. The controller is not water-proof or shock-proof, and as such should not be exposed to direct water contact or extremely high moisture.

8. DO NOT attempt repair. Any factory serviceable parts of this controller are only to be repaired or replaced by the manufacturer or other authorized agencies.

9. If the power cable insulation is broken, please stop using the product. Immediately unplug the controller and contact the retailer from whom you purchased the unit. 10. The controller is equipped with a circuit breaker for short-circuit or over-current situations. The circuit breaker will automatically shut down the product at once. All outlets of the controller are grounded for safety.

11. Do not block any ventilation openings.

12. This product is a Safety Class I Controller. The main plug should be inserted in a power socket outlet only if provided with a protective earth contact. Any interruption of the protective conductor inside or outside of the product is likely to make the product dangerous and is prohibited.



# Remote CO<sub>2</sub> Sensor





### Sulfur vaporizer warning!

If a sulfur vaporizer is used, first remove the remote sensor from the affected area or turn the controller OFF and cover the remote sensor probe with a protective plastic bag. Remove the bag before turning the power back ON.

Note: Failure to protect the sensor during Sulfur use will result in damage to the infrared CO<sub>2</sub> sensor and void warranty.

#### Note:

Do not place the sensor probe where it will come in to contact with water. NOT WATER PROOF.

### **Available Environment Controller Models:**

#### • Single Function



PPM-B1 (CO<sub>2</sub> PPM Controller)

LIGHT-B1 (Digital Lighting Controller)

TIMER-B1 (Recycle Timing Controller)

**TEMP-B1** (Temperature Controller)

#### **CO<sub>2</sub> Controller** PPM-B1



#### Multi-Function



**BECC-B2** (CO<sub>2</sub>, Humidity, and Temperature) **BETC-B2** (Temperature, Humidity, and Recycle Timer) BTLC-B2 (Lighting Controller and Recycle Timer)



CRS Worldwide B.V. Slimmeweg 7,1066ev, Amsterdam, Netherland